

Modeling analysis and optimization for European network data merging

Manuel Ruiz
Othman Moumni Abdou
Arnaud Renaud
ARTELYS
Paris, France
firstname.lastname@artelys.com

Jean Maeght
Mireille Lefevre
Patrick Panciatici
RTE
Versailles, France
firstname.lastname@rte-france.com

Abstract—In this paper, the problem of building a consistent European network state based on the data provided by different Transmission System Operators (TSOs) is addressed. A hierarchical merging procedure is introduced and consists in the resolution of several Optimal Power Flow problems (OPFs). Results on the European network demonstrate the interest of this procedure on real-life cases and highlight the benefits of using a hierarchical multi-objective approach.

Index Terms—Non Linear Programming; Optimal Power Flow; Power Systems Network Merging; State Estimation

I. INTRODUCTION

One of the main concern of European Transmission System Operators in Europe is keeping the system in a secure state. Security assessment tools help to assess risk in the system and provide preventive and curative actions when necessary. They are performed *ex post* and require a description of the network at an earlier time t . In an ideal case, each TSO would provide *accurate* data, representing the network state at the *exact time* t . A simple power flow computation would then be sufficient to establish the state of the whole network.

Unfortunately, available data are not synchronized between TSOs, input data are snapshot generated each 15 minutes that are always slightly non-synchronized. They can also be missing; in this case they are replaced by the previous snapshot or the forecast made the day before to have a complete description of the network. Thus, non-synchronized and erroneous data have to be collected in real-time and merged in order to build a consistent state of the European network for security assessment. Additionally, the merging must limit the impact of the erroneous data on the consolidation of reliable snapshot data.

The problem of state estimation enhancement [1] leads to the resolution of Optimal Power Flow where the objective is to find a feasible network state minimizing the deviations from the well-estimated parts of the network. This problem has already been considered by RTE, the French TSO, who introduced an objective of minimizing a weighted least squares distance and implemented the OPF in an optimizer for merging European networks. This merging tool is used at **CORESO** (COoRdination of Electricity System Operators) on a day-to-day basis since 2009. More details on power system optimiza-

tion and general OPF formulations can be found in [2], [3]. The work presented in this paper represents possible way of improvement of the CORESO merging tool with the aim to use a multi-objective hierarchical approach. A first study [4] have already been published in this way to evaluate the impact of the deviation measure in the optimization process.

The paper is organized as follows. Section II presents the context of the study and why the **iTesla** project leads to this problematic. After introducing the mathematical formulation of the modified ACOPT in section III, main contributions are detailed in section IV. The hierarchical merging methodology is presented in section V. Finally, computational experiments on large scale power system network are presented in section VI.

II. CONTEXT

A. The *iTesla* project

The Innovative Tools for Electrical System Security within Large Areas (**iTesla**) project is a European research and development project co-funded by the European Commission [5] and involving 6 European TSOs, 13 other R&D providers and several academic partners. The aim of this project is to develop a flexible inter-operable toolbox which is able to support future operations of the pan-European electricity transmission network. This toolbox shall enable to perform:

- Accurate security assessments taking system dynamics into account using time-domain simulations.
- Risk assessments taking into account: uncertainties (especially intermittent power generation uncertainties), probabilities of contingencies and possible failures of corrective actions.

The **iTesla** toolbox includes two main components:

- an off-line platform, running every week, in charge of exploring the network state space to draw the separation between stable and unstable states (using data mining techniques and high-fidelity dynamic simulations). This platform is especially in charge of identifying security rules to apply.

- an on-line platform, running every day, dedicated to security assessment. This second platform evaluates the off-line platform security rules on the current network and issues curative or preventive actions, when necessary.

The whole iTesla workflow is described in the figure 1. The on-line platform is also in charge of acquiring and merging data provided by European TSOs. The work presented in this paper is part of data merging module presented in the following subsection.




Figure 1. The iTesla workflow

B. Data merging

The data merging module is part of the online platform which aims to consolidate TSOs' networks into a single, consistent, merged European network. Result of this module is used as a description of the underlying network to perform security assessments and provide recommendation for TSOs to keep the system in a secure state.

Input data are the result of a topological merge of European TSOs' network data performed with the most reliable data available for time t . The output is a consistent European network state for the time t , minimizing the deviation from the data provided by TSOs.

In the data, the network state for each country is consistent but the whole network is not. One of the reasons is the power flow on interconnections: when a European AC load flow is solved, the active power flow on interconnections is computed using the characteristics of the interconnections and the voltage level of the buses. Computed and measured values are usually different since data from the different TSOs are not perfectly synchronized.

The data provided by each TSO become targets and the aim is to find a feasible merged network state minimizing the deviations from target data. Deviations that are minimized are related to voltage level of bus, active power flow on interconnections and loads.

Additionally, there are different types of data and different levels of confidence:

- Time differences: the aim is to compute a network state at time t but the data provided by the TSOs can be up to one hour older
- There are different reliability levels:
 - 1) Snapshots (SN): data based on real-time observations and measurements on the network. If they are recent, these data are very reliable.
 - 2) Day Ahead Congestion Forecasts (DACF): these are forecasts data for a given time. If a TSO is not able to provide its snapshot data in time, the DACF data (which is provided the day before) are used as a replacement. Obviously these data are less reliable than SN data. Although, using this data must not impact the merging of the SN part of the network; erroneous data must not be spread to the other parts of the network.

Consequently, the merging procedure involves multiple minimization objectives depending on deviation type (voltage levels, active power flows or loads) and data reliability level (SN or DACF). In the following section, the mathematical formulation of network transmission data consolidation is presented.

III. MATHEMATICAL FORMULATION

The power flow is modeled using an AC formulation. The model is similar to the polar PQV ACOPF presented in [2]. Additionally, the loads are decomposed into two parts: a constant part given by TSOs plus a slack variable for the deviation. The deviations model the gap between the values provided by the TSOs and the values in a feasible solution. Two types of buses are distinguished: PV and PQ. For PV buses, active production, voltage and load are given. The active production is fixed and the voltage level and load are used as targets. For PQ buses, active and reactive production and load are specified. The active and reactive production are fixed and load is used as target data. The voltage of PQ buses and the reactive power of PV buses are within their bounds but do not appear in the objectives of optimization models.

In order to measure the deviations from the collected data, different penalty functions can be considered. The study in [4] has evaluated the influence of the norms used as penalty functions in network merging procedure. The results of the study showed that the deviation measures can have a significant impact on how the data are consolidated and how the deviations are spread over the buses and the interconnections.

The deviations are measured using the Manhattan norm, the sum of squares and Huber function. Choice of these penalty functions is based on the results of the study in [4].

The Manhattan norm (L_1) sums the absolute values of the deviations. It helps focusing on minimizing the total sum of the deviations. Additionally, since the impact is linear there is no advantage at modifying several variables preferably to a single variable.

This norm is used to measure the deviation of loads for SN buses (obj_{load}^{sn}). As SN data are assumed to have a good confidence level, it ensures that deviations of loads are focused on a small number of buses. Moreover, it helps to localize problems and analyze the merged network state.

The sum of squares (L_2) favors small modifications over many variables than significant modification on few ones. This prevents the deviations from being too wide. It helps finding a feasible solution within a limited range of the original one which is especially interesting if TSOs data are reliable but can fail to correct a localized error.

This norm is used to measure deviation of voltage levels for PV buses (obj_V) as these data are very reliable. It helps to find feasible solution within a limited range of the original voltage levels.

It is also used as penalty function for deviation of loads for DACF buses (obj_{load}^{dacf}). Since DACF data are used as replacement of SN data and are less reliable, all loads from DACF data are potentially erroneous. Using the sum of squares as penalty function allows to spread deviations over DACF buses.

The Huber function is quadratic for small differences and linear for wide variations. This favors spreading deviations provided they remain small and does not strongly penalize a significant change of a variable. It combines both the advantages of L_1 and L_2 norms. This approach has already been successfully applied in [3]. Additionally, the sum of two Huber functions is constant and minimum over a confidence interval. This is especially interesting if there are different targets for the same data as it is the case for active power flow on interconnections where each neighboring TSO provides a target for a given interconnection.

Therefore, this function is used as penalty function for the deviation of active flows on interconnections ($obj_{interco}$) as it helps take into account two different targets. The variation of active power flow between these two targets have no impact on $obj_{interco}$ unless the variation is wider.

IV. MAIN CONTRIBUTION

The four deviation minimization objectives presented in section III may be conflicting. For example, minimizing the deviation of load for a SN bus connected to an interconnection could increase the deviation of active power flow on this interconnection. In practice, there does not exist a single solution that simultaneously optimizes each objective and thus a trade-off exists between the different objectives.

Classical merging methods, like the one used at **CORESO** uses a single-objective function problem that involves, separately, all the objectives to minimize deviations. This method normalizes the objectives into one single-objective by multiplying each objective with a weight. The set of weights used in such objective could be based on a prioritization of all types of deviations but it will highly influences the quality of the merged network state obtained by spreading deviations over the objectives.

Hence, one can consider using a hierarchical approach by solving successive ACOPFs using different objectives at each step. This method seeks the appropriate trade-off between the different objectives in order to find a feasible network state using the order of preference of the objectives. Moreover, with the advent of more efficient non-linear solvers, considering a hierarchical merging approach has become possible as it is fast enough to be used every 15 minutes in an operational context.

The methodology presented in this paper is successfully applied to the very high voltage European transportation network. Results of tests on real operational data are presented in section VI. In the subsequent section V, the hierarchical approach is detailed.

V. HIERARCHICAL APPROACH

The hierarchical merging procedure consists of solving several successive modified ACOPFs.

One of the main difficulties of this method is how to constraint the problem at each step to the locally optimal solution space of the preferred objectives (objectives of previous steps). In fact, all objectives have to be minimized in a manner such that they do not cause an increase in any of the more preferred objectives. This rule has been relaxed to slightly expand the solution space in order to avoid numerical difficulties as OPF are highly non-convex continuous optimization problems.

In the first step, only the $obj_{interco}$ is used as objective function for the ACOPF model. Since only deviations of active power flows on interconnections are minimized, other data (voltage levels and loads) may be modified without penalization, while respecting the constraints of the ACOPF model. The resulting flows are thus generally within the two targets provided by the TSOs. After this first step, active power flows on interconnections are bounded in the interval containing the two targets and the value obtained in this first step. A tolerance is used to extend the range of accepted values and accept neighboring values.

The second step aims to minimize obj_V , starting from network state obtained in the first step. The resulting merged network state has deviations mainly concentrated on loads since active power flows on interconnections are bounded and deviations on voltage levels of PV buses are minimized. After this second step, voltage levels on PV buses are fixed using a small tolerance.

In the third step, obj_{load}^{sn} is used to minimize the deviations of loads from SN data. The optimization tends to prior modification of DACF loads over SN loads, since there is no penalization associated to loads from DACF data. In the SN perimeter, the use of the L_1 norm helps to localize deviations and avoid making several small deviations. At the end of this step, deviations of loads from SN data are fixed.

In the last step, the only degrees of freedom in the model are loads from DACF data. Flows on interconnections and voltage levels are fixed using tolerances while loads in SN perimeter are fixed. This last step focuses on spreading the deviations of loads on DACF buses by minimizing the objective obj_{load}^{dacf} .

At the end of the hierarchical merging procedure, a consistent merged network state is obtained where deviations from collected data are minimized using the adequate trade-off between the different objectives. The deviations are prioritized using the following order: DACF loads (lowest priority), SN loads, voltage levels of PV buses and then active power flow on interconnections (highest priority).

VI. COMPUTATIONAL EXPERIMENTS

The iTesla toolbox will be operating at a Pan-European level. In this work, data are collected from 15 TSOs in 11 countries. The grid is composed of around 6000 buses, 8500 branches, 3500 loads, 900 production units and about 180 interconnections between the different TSOs' networks. This underlines how challenging the project is.

The hierarchical merging procedure is implemented using AMPL [6] and solved with KNITRO [7], [8].

A. Merging indicators

In order to evaluate the quality of the resulting merged network state, the following indicators are defined to estimate the deviation from TSOs data:

- *Interco SN_SN*: Number of interconnections between two TSOs with SN data where the active power flows are not within the two targets provided by two neighboring TSOs.
- *Interco SN_DACF*: Number of interconnections between a TSO with SN data and a TSO with DACF data such that the active power flows target in the SN data is not satisfied.
- *V SN*: Number of SN buses where voltage level targets are not met.
- *V DACF*: Number of DACF buses where voltage level targets are not satisfied.
- *Loads ACT SN*: Number of SN buses where active load targets are not met.
- *Loads REA SN*: Number of SN buses where reactive load targets are not satisfied.

Acceptable deviation tolerances are used in order to only consider real deviations. The deviation of active power flow on interconnection is non-zero if its absolute value is greater than $5MW$. Concerning voltage levels, only absolute deviations greater than $0.1kV$ are taken into account. Deviations of active loads and reactive loads are non-zero if the absolute value is respectively greater than $1MW$ and $1Mvar$.

B. Experimentation to determine the modeling approach

First experiments allow us to validate the hierarchical merging procedure and ensure that the method gives good merging results on large scale networks. Several modeling approach were tested during these first experiments which allows us to determine the best modeling alternative: choice of penalty functions, definition of the objectives and their hierarchical order, numerical tolerances to avoid infeasibilities, etc. Moreover, a load flow is used in the iTesla toolbox to make sure that the merged network state is feasible and that there

is no modeling inconsistencies between our OPF and standard load-flow.

Three European situations are used:

- **09h30**: Data from the 12th February 2014 at 09h30
- **11h15**: Data from the 12th February 2014 at 11h15
- **08h30**: Data from the 13th February 2014 at 08h30

Some of the snapshots data are missing and DACF data are used to replace them in order to have the full European network:

Country	Code	09h30 status	11h15 status	08h30 status
Austria	AT	SN	DACF	SN
Belgium	BE	SN	SN	SN
Switzerland	CH	SN	SN	SN
Czech republic	CZ	DACF	SN	SN
Germany	DE	Both	Both	Both
France	FR	DACF	SN	SN
Croatia	HR	DACF	DACF	DACF
Italy	IT	SN	SN	SN
Netherlands	NL	SN	SN	SN
Poland	PL	DACF	DACF	DACF
Slovenia	SI	SN	SN	DACF

German network data are snapshot on some parts of the country and DACF on the others. Furthermore, due to TSO actions on the network, the grid topology may change over time, from situation to another.

The indicators presented in the table below show the interest of the hierarchical merging procedure. This method manages to hold targets for active power flow on interconnections and voltage levels of PV buses. Deviations are mainly focused on loads which corresponds to the order of objectives in the hierarchical procedure.

Indicator	09h30	11h15	08h30
<i>Interco SN_SN</i>	3 / 68	3 / 99	3 / 96
<i>Interco SN_DACF</i>	24 / 73	14 / 47	4 / 48
<i>V SN</i>	11 / 242	20 / 455	24 / 451
<i>V DACF</i>	19 / 329	16 / 73	9 / 82
<i>Loads ACT SN</i>	26 / 1914	43 / 2859	39 / 2806
<i>Loads REA SN</i>	14 / 1884	40 / 2848	34 / 2797

For the 09h30 situation, 3 SN_SN interconnections over 68 have deviations greater than $5MW$. Although, these deviations remains small. In fact, the maximum deviation from the two targets of SN_SN interconnections (L_TARGET and U_TARGET) is $7MW$ and $9MW$ from SN_DACF interconnections with a target from the SN side. These deviations are relatively small compared to active power flow on interconnection which reaches $1450MW$ as we can see in figures 2 and 3. These two figures represent active power flows on interconnections ordered in function of target values. One can see that the active power flows remains very close to the target values. Concerning the voltage level, the maximum deviation is $0.37kV$ located on a DACF bus. Only 11 SN PV buses have a deviation larger than $0.01kV$. Regarding loads, the

deviations of active load for SN buses (figure 4) are up to $77MW$. Even if the maximum deviation is high, this is the expected behavior when using the L_1 norm. Indeed, deviations are local and have a large magnitude.

For the 08h30 and 11h15 situations, the analysis is similar to 09h30 situation. The indicators are proportionally comparable to the 09h30 situation when taking into account the grid topology. In the 11h15 situation, the maximum deviation of active power flow on interconnections is equal to $6MW$ for SN_SN interconnections and $12MW$ for SN_DACF interconnections. Small deviations are detected on voltage level where the maximum value is $0.14kV$. In the 08h30 situation, maximum deviation of active power flow on interconnections is equal to $8MW$ for SN_SN interconnections and $6MW$ for SN_DACF interconnections while deviations of voltage level are up to $0.25kV$.




Figure 2. Deviations of active power flow on SN_SN interconnections for the 09h30 situation

C. Robustness against data errors

Second experiment intends to test the robustness of the hierarchical approach against data errors. The aim of this experiment is to make sure that the introduction of DACF data, poorly reliable, does not affect the merging of the SN part of the network.

The 09h30 situation presented in VI-B is used for this experiment. Two situations are compared: the initial situation (09h30) and the situation where SN data from Netherlands (NL) is replaced by DACF data (09h30 modified). Hence, 3 parts of the network are distinguished: the SN part in the two situations, the DACF part in the two situations and the NL network which SN in 09h30 and DACF in 09h30 modified.




Figure 3. Deviations of active power flow on SN_DACF interconnections for the 09h30 situation




Figure 4. Deviations of active SN loads for the 09h30 situation

These 3 parts of the network are used for computing our indicators.

The indicators presented in the following table show that SN part of the network is not affected by the introduction of DACF data.

Indicator	09h30	09h30 modified
V_{SN}	11 / 231	44 / 231
V_{NL}	0 / 11	0 / 20
Loads ACT SN	23 / 1284	22 / 1284
Loads ACT NL	3 / 630	6 / 273
Loads REA SN	12 / 1229	11 / 1229
Loads REA NL	2 / 655	13 / 275

Interconnections are not impacted by the introduction of DACF data. The number of deviations of active power flow on interconnections besides NL interconnections is the same for the two situations. The number of deviations of voltage levels for SN buses is more important in the modified situation but maximum deviation remains comparable with the initial situation ($0.13kV$ in 09h30 and $0.15kV$ in 09h30 modified). Regarding loads, results show that the number of deviations of active load and reactive load for SN buses remains stable between the two situations. We also note that the network

topology of the NL DACF data is different from the one used in the initial situation (e.g. 11 PV buses in 09h30 and 20 in 09h30 *modified*). Moreover, when NL data are DACF the number of deviations in the NL part of the grid is more important proportionally to the size of the NL network.

This experiment shows that the hierarchical merging procedure successfully consolidates the data even when some snapshot data are missing and replaced with DACF data. The use of the DACF data, less reliable than the SN data does not impact the consolidation in the SN part of the network.

D. Numerical robustness

Third experiment aims to check the robustness of the hierarchical approach compared to the merging procedure used at CORESO. The merging tool deployed at CORESO usually fails less than 1% of the time due to numerical difficulties. On a week of July 2015, the number of failures have reached 5%. The set of situations used in this third experiment corresponds to this week of data: 672 situations which corresponds to a situation, every 15 minutes of the 7 days. Results of this experiment shows that the hierarchical merging approach is as reliable as the merging procedure used at CORESO.

VII. CONCLUSION

In this paper, a hierarchical merging procedure solving several successive ACOPFs is introduced to build a consistent merged network state by minimizing the deviations from the data provided by the different TSOs. The aim of this approach is to make the right trade-off between the different objectives defined in function of deviation type (voltage levels, active power flows or loads) and data reliability level (SN or DACF). The experiments on the European network have shown the interest of this approach to obtain a consistent feasible merged network state. They also demonstrate the robustness of such approach when dealing with data errors. The quality of the DACF data (used as replacement when SN data are not available) does not influence the merging quality on the SN part of the network. Moreover, the method have been compared to the merging procedure used in CORESO. The results exhibit that the hierarchical merging procedure is reliable.

Further work may improve the hierarchical merging procedure by detecting Phase-Shifting Transformer configurations errors and correct them using an optimization process. Another way of improvement could be the use of the previous merged network state as a replacement of SN data or as an initial point from the optimization process.

REFERENCES

- [1] M. Dancre, P. Tournebise, P. Panciatici, and F. Zaoui, "Optimal power flow applied to state estimation enhancement," in *Proc. 14th Power Systems Comput. Conf.*, 2002.
- [2] M. B. Cain, R. P. O'Neill, and A. Castillo, "History of optimal power flow and formulations," Federal Energy Regulatory Commission, Tech. Rep., 2012. [Online]. Available: <http://www.ferc.gov/industries/electric/indus-act/market-planning/opf-papers/acopf-1-history-formulation-testing.pdf>
- [3] S. Fliscounakis, "Influence of parameter accuracy on estimated resistive losses," *IEEE PES France, Proceedings of the RTE-VT Workshop on State Estimation and Forecasting Techniques*, 2006.
- [4] M. Ruiz, M. Gabay, J. Maeght, M. Lefevre, and P. Panciatici, "Optimization based method to consolidate european transmission data," in *PowerTech, 2015 IEEE Eindhoven*, June 2015.
- [5] itesla project website. Project supported by the European Commission under the 7th Framework Programme. [Online]. Available: <http://www.itesla-project.eu/>
- [6] R. Fourer, D. M. Gay, and B. W. Kernighan, *AMPL: A Modeling Language for Mathematical Programming*. Duxbury Press, Nov. 2002. [Online]. Available: <http://ampl.com/resources/the-ampl-book/chapter-downloads/>
- [7] R. H. Byrd, M. E. Hribar, and J. Nocedal, "An interior point algorithm for large scale nonlinear programming," *SIAM Journal on Optimization*, 1999.
- [8] R. H. Byrd, J. C. Gilbert, and J. Nocedal, "A trust region method based on interior point techniques for nonlinear programming," *Mathematical Programming*, vol. 89, no. 1, pp. 149–185, 2000.